



Certificate of Compliance

Certificate: 70103418

Master Contract: 264700 (264700)

Project: 70103418

Date Issued: 2017-10-03

Issued to: **Energo Group Canada Inc.**
1110 - 1 Street SW
Calgary, Alberta T2R 0V1
CANADA
Attention: Dragan Lemez

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Douglas Bramwell*
Douglas Bramwell

PRODUCTS

CLASS 5411 06 – TRANSFORMERS – Power

High voltage power transformer, Model MVROT-250, primary rated 4160 Vac; secondary rated 2500 Vac, 185 kVA, 30 kV BIL, Insulation Class H. Additional secondary windings: Measuring (voltage), rated 120 V, 50 VA; Control, rated 120 V, 3%, 300 VA; Current, rated 10 VA, 60:1.

Notes:

1. These transformers are provided without an enclosure. Final acceptance of installation to be determined by the authorities having jurisdiction.
2. The evaluation of the instrument transformers windings cover electrical shock hazards only. Performance was not evaluated.

APPLICABLE REQUIREMENTS

C22.2 No. 47-13 – Air Cooled Transformers (Dry Type)



Supplement to Certificate of Compliance

Certificate: 70103418

Master Contract: 264700 (264700)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70103418	2017-10-03	High Voltage Power Transformer, Model MVROT-250.