

CIGRE – 299

MANITOBA HYDRO, ESTELLA SUBSTATION, MVROT PILOT PROJECT FOR THE ENERGY EFFICIENCY AND REDUCTION OF LOSSES IN ELECTRICAL POWER DISTRIBUTION GRIDS “THE MVROT PROJECT”

Authors:

- A. Lemez, B.Sc. - Energo-Group d.o.o., Sarajevo, Bosnia and Herzegovina**
- D. Lemez, B.Sc. - Energo Group Canada Inc., Calgary, AB – Canada**

Presenting:

Dragan Lemez

CIGRE – 299

MANITOBA HYDRO, ESTELLA SUBSTATION, MVROT PILOT PROJECT FOR THE ENERGY EFFICIENCY AND REDUCTION OF LOSSES IN ELECTRICAL POWER DISTRIBUTION GRIDS “THE MVROT PROJECT”

EGC Patents Implemented on the Project:

USPTO Patent # 10,205,318:

Method and System for reducing losses during electrical power distribution

Effective Feb. 12, 2019

Total claims 18

USPTO Patent # 10,650,954:

Losses Reduction for Electrical Power Distribution

Effective May 12, 2020

Total claims 28

USPTO Patent # 10,763,029:


Losses Reduction for Electrical Power Distribution - MVROT

Effective September 01, 2020

Total claims 11



INTRODUCTION / PROJECT GOALS



Parties Introduction



- Manitoba Hydro (MH)
Estella Substation
Field crew
- Energo Group Canada (EGC)
MVROT Pilot Project
Method and System

Project goals

- **Safety:** Elimination of currents in neutral line and circuit currents
- **Quality:** Voltage stability in long runs, balancing phase loads
- **Efficiencies:** Reduced voltage drops, power losses, more energy to deliver
- **Visibility:** Automatization and control, grid selectivity protection
- **Future expansion:** Capital investment for reconstruction reduced


FIELD PROGRAM

DATA RECORDED	EQUIPMENT USED	DATA COLLECTED
<p><u>At Substation J207 feeder</u> <u>(With and Without MVROT):</u></p> <ul style="list-style-type: none"> Regulated Phase Voltages: APH, BPH, CPH, Amperage: IA, IB, IC, IN <p><u>At MVROT location</u> <u>(Phase B branch - bypass):</u></p> <ul style="list-style-type: none"> Phase output Voltage: BPH Amperage: IA, IB, IN, Ia Line Voltage: UAB 	<ul style="list-style-type: none"> Aclara Sensors at Substation For phase voltage and amperage Aclara Sensors at MVROT location For phase voltage and amperage Cooper sensors at MVROT location For amperage HIOKI 3196 analyser at MVROT location Rogowski CT at MVROT location Voltage Instrument Transformer (ABB) at MVROT location MVROT-250-4.16//2.4 (185kVA) 	<p><u>Baseline Records (Without MVROT):</u> From Jan 02, 2020 to Jan 09, 2020</p> <p><u>Second Records with MVROT:</u> From Jan 28, 2020 to Feb 06, 2020</p> <p>All records collected at 15min 24h/day</p> <p>Total nominal power at the pilot project location branch is 162kVA</p>




Note: MVROT is NOT an autotransformer

VOLTAGE & ENERGY EFFICIENCIES ANALYSIS



“Figure 2a” shows, Phase “B”, phase voltage (2.4kV nominal) records.

https://www.egcanada.ca/PDF/Publishings%20Page/PilotProj/2a-GRAPHICAL%20REPRESENTATION%20OF%20MVROT_Voltage%20Efficiency%20Analyses_28-JAN%20to%2006-FEB%202020.pdf



“Figure 2b” shows, Phase “B”, energy efficiency percentage increase with MVROT energized.

https://www.egcanada.ca/PDF/Publishings%20Page/PilotProj/2b-GRAPHICAL%20REPRESENTATION%20OF%20MVROT_Energy%20Efficiency%20Analyses_28-JAN%20to%2006-FEB%202020.pdf

ENERGY EFFICIENCIES ANALYSIS

<p><u>With MVROT energized:</u></p>	$W_1/W_2 = (U_1/U_2)^2$ $W_1 = (U_1/U_2)^2 * W_2$ $W_1 = k_1 * W_2$	<ul style="list-style-type: none"> • W_1=delivered energy to the end users. • W_2=energy that would be delivered to the end users if voltage level at MVROT location is equal to Substation (Ideal conditions). • k_1=Voltage ratio “$(U_1/U_2)^2$”; Records are showing improved voltage in feeder which resulted in “k_1” voltage ratio > 1. • Reduced power losses and requires less time required to deliver demanded power.
<p><u>Without MVROT energized:</u></p>	$W_3/W_4 = (U_3/U_4)^2$ $W_3 = (U_3/U_4)^2 * W_4$ $W_3 = k_2 * W_4$	<ul style="list-style-type: none"> • W_3 = delivered energy to the end users. • W_4 = energy that would be delivered to the end users if voltage level at MVROT location is equal to Substation (Ideal conditions). • k_2 = Voltage ratio “$(U_3/U_4)^2$”; The baseline records are showing voltage drops in feeder, resulting in “k_2” voltage ratio < 1. • Accrued power losses and requires more time to deliver demanded power.
<p><u>Energy Efficiency</u></p>	$E_f = (k_1-1) * 100 + (1-k_2) * 100$	<ul style="list-style-type: none"> • E_f = Energy Efficiency Percentage change; (total percentage of voltage change)

Table 2: Energy efficiency calculations

Recorded actual data:

- U_1 = BPH [V]: VOLTAGE RECORDS AT PILOT LOCATION WITH MVROT ENERGIZED
- U_2 = BPH [V]: REGULATED PHASE “B” VOLTAGE AT SS WITH MVROT ENERGIZED
- U_3 = BPH [V]: BASELINE VOLTAGE RECORDS AT PILOT LOCATION WITHOUT MVROT
- U_4 = BPH [V]: REGULATED PHASE "B" VOLTAGE AT SS WITHOUT MVROT

VOLTAGE & ENERGY EFFICIENCIES RESULTS

PHASE / DATA	BASELINE	WITH MVROT	IMPROVEMENTS*
Maximum Phase Voltage [V]	2451.5	2553.5	+102 [V] or (4.16%)
Minimum Phase Voltage [V]	2360.5	2481.0	+120.5 [V] or (5.10%)
Maximum Low Voltage [V]	122.58	127.68	+5.1 [V] or (4.16%)
Minimum Low Voltage [V]	118.03	124.05	+6.02 [V] or (5.10%)
Max voltage [V] drop [-] / improved [+]	-33.72	+146.50	-
Min voltage [V] drop [-] / improved [+]	-88.00	+53.50	-
Min / Max Increased voltage % -With MVROT			4.16% / 5.10%
Min / Max / Avrg. efficiency increased -With MVROT			6.34% / 10.04% / 8.31%

*Positive values are voltage improvements within allowable limits


“Table 1” Significant records and results associated with Figure 2a and Figure 2b graphs.

INCREASED ENERGY EFFICIENCY [%] WITHIN MEASURED TIME INTERVALS

=


INCREASED PROFIT [%] WITH MVROT ENERGIZED

AMPERAGE ANALYSIS @ ESTELLA S/S




“Figure 3a”
Baseline amperage records in phase « A », « B » and neutral
https://www.egcanada.ca/PDF/Publishings%20Page/PilotProj/3a-Amperage%20at%20Estella%20Substation%20BASELINE%20-%20NO%20MVROT%20Analyses_02-JAN-2020%20to%2009-JAN-2020.pdf

“Figure 3b”
With MVROT amperage records in phase « A », « B » and neutral
https://www.egcanada.ca/PDF/Publishings%20Page/PilotProj/3b-Amperage%20at%20Estella%20Substation%20WITH%20MVROT%20Analyses_30-JAN-2020%20to%2006-FEB-2020.pdf



“Figure 4a”
differences between amperages within neutral conductor
https://www.egcanada.ca/PDF/Publishings%20Page/PilotProj/4a-Amperage%20in%20NEUTRAL%20at%20Estella%20Substation%20BASELINE%20and%20WITH%20MVROT%20Analyses_02-JAN-2020%20to%2006-FEB-2020.pdf




AMPERAGE ANALYSIS RESULTS @ S/S

PHASE / DATA	BASELINE	WITH MVROT	IMPROVEMENTS*
Maximum Amperage Phase A [A]	164.14	174.29	10.15 [A]
Minimum Amperage Phase A [A]	73.41	83.31	9.9 [A]
Maximum Amperage Phase B [A]	207.60	173.24	-34.36 [A]
Minimum Amperage Phase B [A]	89.80	80.02	-9.78 [A]
Maximum Amperage Neutral [A]	94.71	65.90	-28.81 [A]
Minimum Amperage Neutral [A]	30.16	11.74	-18.42 [A]
Min / Max reduction in Neutral [A]	-	-4.04 / 52.7	-
Neutral load [%] reduction trendline	-	29% and 39%	-
Overall percentage of energy efficiency	-	8.7%	-

*Positive values in IMPROVEMENTS column are amperage increase; negative values are amperage decrease achieved with MVROT energized. Negative values are representing phase/neutral line improvements.

Table 3: Significant records associated with graphs shown in Figures 3a through Figure 4a

AMPERAGE ANALYSIS @ MVROT LOCATION




“Figure 5a”
load in phases “A” and “B” at primary side of MVROT

https://www.egcanada.ca/PDF/Publishings%20Page/PilotProj/5a%20-%20Amperage%20analyses%20at%20MVROT%20location%20-%20Phase%20A%20and%20phase%20B%20loads%20with%20MVROT%20energized_30-JAN%20to%2006-FEB%202020.pdf


“Figure 5b”
amperage in MVROT secondary phase “a”

https://www.egcanada.ca/PDF/Publishings%20Page/PilotProj/5b%20-%20Amperage%20analyses%20at%20MVROT%20location%20-%20MVROT%20Secondary%20Phase%20a%20and%20Neutral%20loads%20with%20MVROT%20energized_30-JAN%20to%2006-FEB%202020.pdf



“Figure 5c”
differences between amperages within neutral conductor

https://www.egcanada.ca/PDF/Publishings%20Page/PilotProj/5c%20-%20Amperage%20analyses%20at%20MVROT%20location%20-%20Amperage%20changes%20in%20lines%20to%20substation%20with%20MVROT%20energized_30-JAN%20to%2006-FEB%202020.pdf




AMPERAGE ANALYSIS @ MVROT LOCATION

- I_{B1} = MVROT IA INPUT COOPER [A] WITH MVROT
- I_{B2} = MVROT IB INPUT COOPER [A] WITH MVROT
- I_{B3} = MVROT OUTPUT COOPER [A] WITH MVROT
- I_{B4} = ROGOWSKI - NEUTRAL AVERAGE 15 MINUTES CURRENTS [A] WITH MVROT

Without MVROT: Recorded amperages (I_{B3} , I_{B4}) are closing circuit all the way to the substation.

With MVROT energized: These amperages are transformed into I_{B1} and I_{B2} by MVROT, and I_{B1} and I_{B2} are closing circuit all the way to the substation instead.



Schematics of line amperages at MVROT location

- I_A : $I_{B1} - I_{B3}$ (reduction of I_{B3} amperages that would go all the way to the substation)
- I_B : $I_{B2} - I_{B4}$ (reduction of I_{B4} amperages that would go all the way to the substation)

Total amperage changed through these two conductors is an addition of these two: $I_A + I_B$

Losses in lines are:

$$P_v = r_v * I^2$$

- Without MVROT: $I_1^2 = I_{B3}^2 + I_{B4}^2$; $P_{v1} = r_v * I_1^2$

- With MVROT: $I_2^2 = I_{B1}^2 + I_{B2}^2$; $P_{v2} = r_v * I_2^2$


Relationship between the losses in line without MVROT and with MVROT is: $P_{v1} = K * P_{v2}$

- P_{v1} - line losses without MVROT

- P_{v2} - line losses with MVROT

$$K = P_{v1} / P_{v2} = (I_{B3}^2 + I_{B4}^2) / (I_{B1}^2 + I_{B2}^2) = I_1^2 / I_2^2$$

POWER LOSSES REDUCED



“Figure 5d”

https://www.egcanada.ca/PDF/Publishings%20Page/PilotProj/5d%20-%20Amperage%20analyses%20at%20MVROT%20location%20-%20Power%20losses%20ratio%20in%20lines%20without%20MVROT%20_%20with%20MVROT%20energized_30-JAN%20to%2006-FEB%202020.pdf

With the loss's ratio > 1 , the feeder has larger losses without MVROT than with MVROT. For the whole monitoring time, these loss's ratios are always larger than 1. Max: = 3.3098 and Min: = 1.3583.

Number of events in one week that total amperage changes are greater with MVROT installed in this feeder is **7, with maximum increased losses of 0.82 [A]**
 Number of events in one week that total amperage changes are smaller with MVROT installed in this feeder: **661, with maximum reduced losses of -27.50 [A]**

SIGNIFICANT RESULTS AND ECONOMICS

Significant Results:

- On average increased feeder energy efficiency between 8.2% and 8.7%.
- Improved phase voltage levels (~ 4.45%) at load side of MVROT.
- Reduced overall amperage in system neutral line at substation between 29% and 39%.
Maximum amperage in neutral line before MVROT was 94[A] and with MVROT 68[A].
- Load balanced between phase A and B as we did not utilize phase C at all with this Project.
- Reduction in surges from Max. 207.6 [A] before MVROT to Max. 173.24 [A] with MVROT.
- Maximum power losses reduction of 38.22% at one point in time.

Economic Benefits:

- Balancing entire three phase distribution system with many single-phase take-offs.
- Quality of power delivered
- Selectivity of distribution grid
- Increased grid protection and reduce number of outages
- Increased energy efficiency, more energy available for retail
- Extended distribution life and distribution coverage
- Increased safety by eliminating currents in neutral and circuit currents in the ground
- Instrumentation transformers are built in as integral part of MVROT
- Minimum to no Maintenance
- Small capital investments for reconstruction of the existing grids / building new ones

CONCLUSION

- MVROT technology demonstrated extremely successful records and results.
- These field data records and results are validation of the EGC's patented technology.
- "Baseline / MVROT energized" records show significant improvements in this feeder:
 - Improved Voltage,
 - Amperages in phase lines reduced,
 - Amperage in system neutral eliminated / reduced,
 - Feeder Energy efficiency increased,
 - Power and Energy Losses reduced,
 - Grid selectivity achieved,
 - Three phase load balanced
- This technology is technically and economically superior for dealing with:
 - poor quality power, unbalanced systems, and overloaded distribution systems.
- Applicable in any medium voltage grids. (up to 25kV).
- All these benefits above were addressed in published White Paper at 2018 CIGRÉ Canada Conference in Calgary, and with Pilot Project field results they are validated in the live grid.
- Full field results and report is located at our website:

<https://www.egcanada.ca/PilotProject.html>

Q & A

